



LPS
LINWOOD PUBLIC SCHOOLS

Seaview Elementary School
Belhaven Middle School
Linwood, NJ 08221
609.926.6700
www.linwoodschoools.org
@LinwoodSchools

November 16, 2021

Dear Linwood School Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our community and be in compliance with the Department of Education regulations, our District tested our schools' drinking water for lead. The purpose of the sampling was to identify and address any drinking water location above the EPA action level of 15.5 parts per billion (ppb). A drinking water location is an outlet that is designed or expected to be used for water consumption. These included, but were not limited to, classroom water fountains and sinks, water coolers, sinks in nurse's offices, faculty break rooms, and locations in kitchens used for food preparation. Bathroom, custodial, art room, and science room sinks were not sampled, as these are not expected, nor designed to be used for, water consumption.

Water was allowed to stay motionless in each facility for a minimum of eight hours prior to sampling. After this time of inactivity, an "initial draw" sample was collected from the first water to come out of the outlet. After this sample was collected, water was allowed to flush for the required amount of time, and a second "flush" sample was collected. The purpose of the flush sample is to help determine if contamination does exist, whether it is originating from the outlet itself or from the building's plumbing. Of the 83 samples taken, all but six (6) tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15 µg/l [ppb]). A summary of each location above the action level, as well as the short-term response, is found below:

Belhaven Middle School SAMPLE LOCATION	FIRST DRAW RESULT	FLUSH SAMPLE RESULT	SHORT TERM RESPONSE
SINK – KITCHEN REAR RIGHT	25.5 ppb	1.06 ppb	Taken out of service
SINK – KITCHEN RIGHT BY STOVE	44.8 ppb	ND	Taken out of service
SINK – KITCHEN RIGHT FRONT	19.3 ppb	1.13 ppb	Taken out of service
BUBBLER – HALL RIGHT BY KITCHEN	105 ppb	N/A	Taken out of service
BUBBLER – HALL LEFT BY KITCHEN	23.9 ppb	N/A	Taken out of service

Seaview Elementary School SAMPLE LOCATION	FIRST DRAW RESULT	FLUSH SAMPLE RESULT	SHORT TERM RESPONSE
BUBBLER – ROOM C08	99.4 ppb	ND	Taken out of service

Any location requiring corrective actions will be tested prior to being placed back into service.

For More Information

A copy of the test results is available on our website at www.linwoodschoools.org For more information about water quality in our schools, contact the Business Administrator's Office at 609.926.6700.

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at www.epa.gov/lead, call the National Lead Information Center at 800-424-LEAD, or contact your healthcare provider.

Sincerely,

A handwritten signature in blue ink, appearing to read 'Brian M. Pruitt', with a large, stylized flourish at the end.

Brian M. Pruitt
Superintendent of Schools



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

James Eberts
Epic Environmental Services, LLC
80 Fork Bridge Road
Pittsgrove, NJ 08318

10/5/2021

Phone: (856) 205-1077
Fax: (856) 205-0413

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 9/8/2021. The results are tabulated on the attached data pages for the following client designated project:

Project ID: NJ DOE
Belhaven Middle School

The reference number for these samples is EMSL Order #012110528. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012110528
 CustomerID: EPIC62
 CustomerPO: NJ-DOE
 ProjectID: NJ DOE

Attn: **James Eberts**
Epic Environmental Services, LLC
80 Fork Bridge Road
Pittsgrove, NJ 08318

Phone: (856) 205-1077
 Fax: (856) 205-0413
 Received: 9/8/2021 09:00 AM

Project: **Belhaven Middle School**

Analytical Results

Client Sample Description BMS-FB
 Field Blank
Collected: 9/3/2021 9:57:00 AM
Lab ID: 012110528-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 ppb	9/27/2021 VD	9/27/2021 VD 21:03

Client Sample Description BMS-01-WC-HALL1
Collected: 9/3/2021 9:59:00 AM
Lab ID: 012110528-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 ppb	9/27/2021 VD	9/27/2021 VD 21:11

Client Sample Description BMS-02-WC-HALL1
Collected: 9/3/2021 10:02:00 AM
Lab ID: 012110528-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 ppb	9/27/2021 VD	9/27/2021 VD 21:12

Client Sample Description BMS-01-SO-404
Collected: 9/3/2021 10:04:00 AM
Lab ID: 012110528-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.22	1.00 ppb	9/27/2021 VD	9/27/2021 VD 21:14

Client Sample Description BMS-01-SO-404R
Collected: 9/3/2021 10:06:00 AM
Lab ID: 012110528-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.26	1.00 ppb	9/27/2021 VD	9/27/2021 VD 21:15

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012110528

CustomerID: EPIC62

CustomerPO: NJ-DOE

ProjectID: NJ DOE

Attn: **James Eberts**
Epic Environmental Services, LLC
80 Fork Bridge Road
Pittsgrove, NJ 08318

Phone: (856) 205-1077
 Fax: (856) 205-0413
 Received: 9/8/2021 09:00 AM

Project: Belhaven Middle School

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
BMS-01-SO-NUR		9/3/2021 10:09:00 AM		012110528-0008			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 ppb	9/27/2021	VD	9/27/2021	VD 21:17
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
BMS-01-SO-NURR		9/3/2021 10:10:00 AM		012110528-0010			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 ppb	9/27/2021	VD	9/27/2021	VD 21:18
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
BMS-01-DW-HALL1		9/3/2021 10:21:00 AM		012110528-0012			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 ppb	9/27/2021	VD	9/27/2021	VD 21:20
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
BMS-01-DW-HALL2		9/3/2021 10:21:00 AM		012110528-0014			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	10.8	1.00 ppb	9/27/2021	VD	9/27/2021	VD 21:21
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
BMS-02-DW-HALL1		9/3/2021 10:26:00 AM		012110528-0016			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 ppb	9/27/2021	VD	9/27/2021	VD 21:23



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order:	012110528
CustomerID:	EPIC62
CustomerPO:	NJ-DOE
ProjectID:	NJ DOE

Attn: **James Eberts**
Epic Environmental Services, LLC
80 Fork Bridge Road
Pittsgrove, NJ 08318

Phone: (856) 205-1077
 Fax: (856) 205-0413
 Received: 9/8/2021 09:00 AM

Project: **Belhaven Middle School**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
BMS-02-DW-HALL2		9/3/2021 10:27:00 AM	012110528-0018				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	1.82	1.00 ppb	9/23/2021	KG	9/24/2021 13:47	JW
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
BMS-01-SO-SUPR		9/3/2021 10:31:00 AM	012110528-0020				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 ppb	9/27/2021	VD	9/27/2021 21:24	VD
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
BMS-01-SO-CST		9/3/2021 10:32:00 AM	012110528-0022				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	5.03	1.00 ppb	9/27/2021	VD	9/27/2021 21:31	VD
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
BMS-01-SO-MAIN		9/3/2021 10:34:00 AM	012110528-0024				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	1.05	1.00 ppb	9/27/2021	VD	9/27/2021 21:33	VD
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>				
BMS-01-WC-LOBBY		9/3/2021 10:39:00 AM	012110528-0026				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 ppb	9/27/2021	VD	9/27/2021 21:34	VD



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>

EnvChemistry2@emsl.com

EMSL Order:	012110528
CustomerID:	EPIC62
CustomerPO:	NJ-DOE
ProjectID:	NJ DOE

Attn: **James Eberts**
Epic Environmental Services, LLC
80 Fork Bridge Road
Pittsgrove, NJ 08318

Phone: (856) 205-1077
 Fax: (856) 205-0413
 Received: 9/8/2021 09:00 AM

Project: Belhaven Middle School

Analytical Results

Client Sample Description BMS-01-BF-LOBBY **Collected:** 9/3/2021 10:39:00 AM **Lab ID:** 012110528-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 ppb	9/27/2021 VD	9/27/2021 VD 21:36

Client Sample Description BMS-01-SO-MEDIA **Collected:** 9/3/2021 10:41:00 AM **Lab ID:** 012110528-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.81	1.00 ppb	9/27/2021 VD	9/27/2021 VD 21:37

Client Sample Description BMS-01-IM-KIT **Collected:** 9/3/2021 10:45:00 AM **Lab ID:** 012110528-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.19	1.00 ppb	9/27/2021 VD	9/27/2021 VD 21:39

Client Sample Description BMS-01-SO-KIT1 **Collected:** 9/3/2021 10:46:00 AM **Lab ID:** 012110528-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	29.5	1.00 ppb	9/27/2021 VD	9/27/2021 VD 21:40

Client Sample Description BMS-01-SO-KIT1 (FLUSH) **Collected:** 9/3/2021 10:46:00 AM **Lab ID:** 012110528-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.06	1.00 ppb	9/30/2021 VD	9/30/2021 VD 22:57

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012110528
 CustomerID: EPIC62
 CustomerPO: NJ-DOE
 ProjectID: NJ DOE

Attn: **James Eberts**
Epic Environmental Services, LLC
80 Fork Bridge Road
Pittsgrove, NJ 08318

Phone: (856) 205-1077
 Fax: (856) 205-0413
 Received: 9/8/2021 09:00 AM

Project: **Belhaven Middle School**

Analytical Results

Client Sample Description BMS-01-SO-KIT2 **Collected:** 9/3/2021 10:49:00 AM **Lab ID:** 012110528-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.4	1.00 ppb	9/27/2021 VD	9/27/2021 VD 21:42

Client Sample Description BMS-01-KF-KIT **Collected:** 9/3/2021 10:50:00 AM **Lab ID:** 012110528-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 ppb	9/23/2021 KG	9/24/2021 JW 13:49

Client Sample Description BMS-01-SO-KIT4 **Collected:** 9/3/2021 10:52:00 AM **Lab ID:** 012110528-0037

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	44.8	1.00 ppb	9/27/2021 VD	9/27/2021 VD 21:46

Client Sample Description BMS-01-SO-KIT4 (FLUSH) **Collected:** 9/3/2021 10:52:00 AM **Lab ID:** 012110528-0038

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 ppb	9/30/2021 VD	9/30/2021 VD 22:59

Client Sample Description BMS-01-SO-KIT5 **Collected:** 9/3/2021 10:55:00 AM **Lab ID:** 012110528-0039

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	15.1	1.00 ppb	9/30/2021 VD	9/30/2021 VD 18:27

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012110528
 CustomerID: EPIC62
 CustomerPO: NJ-DOE
 ProjectID: NJ DOE

Attn: **James Eberts**
Epic Environmental Services, LLC
80 Fork Bridge Road
Pittsgrove, NJ 08318

Phone: (856) 205-1077
 Fax: (856) 205-0413
 Received: 9/8/2021 09:00 AM

Project: **Belhaven Middle School**

Analytical Results

Client Sample Description BMS-01-SO-KIT6 **Collected:** 9/3/2021 10:56:00 AM **Lab ID:** 012110528-0041

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	19.3	1.00 ppb	9/30/2021 VD	9/30/2021 VD 18:34

Client Sample Description BMS-01-SO-KIT6 (FLUSH) **Collected:** 9/3/2021 10:56:00 AM **Lab ID:** 012110528-0042

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.13	1.00 ppb	10/4/2021 VD	10/4/2021 VD 16:01

Client Sample Description BMS-01-DW-GIRLS **Collected:** 9/3/2021 10:59:00 AM **Lab ID:** 012110528-0043

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	11.5	1.00 ppb	9/30/2021 VD	9/30/2021 VD 18:36

Client Sample Description BMS-01-DW-HALL3 **Collected:** 9/3/2021 11:04:00 AM **Lab ID:** 012110528-0045

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.52	1.00 ppb	9/30/2021 VD	9/30/2021 VD 18:37

Client Sample Description BMS-01-DW-HALL4 **Collected:** 9/3/2021 11:05:00 AM **Lab ID:** 012110528-0047

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.90	1.00 ppb	9/30/2021 VD	9/30/2021 VD 18:39

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012110528

CustomerID: EPIC62

CustomerPO: NJ-DOE

ProjectID: NJ DOE

Attn: **James Eberts**
Epic Environmental Services, LLC
80 Fork Bridge Road
Pittsgrove, NJ 08318

Phone: (856) 205-1077
 Fax: (856) 205-0413
 Received: 9/8/2021 09:00 AM

Project: Belhaven Middle School

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
BMS-01-DW-HALL6		9/3/2021 11:08:00 AM		012110528-0049	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	5.26	1.00 ppb	9/30/2021 VD	9/30/2021 VD 18:40
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
BMS-01-DW-HALL5		9/3/2021 11:08:00 AM		012110528-0051	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	14.2	1.00 ppb	9/30/2021 VD	9/30/2021 VD 18:42
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
BMS-01-WC-HALL7		9/3/2021 10:17:00 AM		012110528-0053	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	105 D	5.00 ppb	9/30/2021 VD	10/1/2021 VD 08:25
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
BMS-01-WC-HALL8		9/3/2021 10:17:00 AM		012110528-0054	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	23.9	1.00 ppb	9/30/2021 VD	10/1/2021 VD 08:26

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **James Eberts**
Epic Environmental Services, LLC
80 Fork Bridge Road
Pittsgrove, NJ 08318

10/2/2021

Phone: (856) 205-1077

Fax: (856) 205-0413

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 9/8/2021. The results are tabulated on the attached data pages for the following client designated project:

Project ID: NJ DOE
Seaview Elementary School

The reference number for these samples is EMSL Order #012110575. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012110575

CustomerID: EPIC62

CustomerPO: NJ-DOE

ProjectID: NJ DOE

Attn: **James Eberts**
Epic Environmental Services, LLC
80 Fork Bridge Road
Pittsgrove, NJ 08318

Phone: (856) 205-1077
 Fax: (856) 205-0413
 Received: 9/8/2021 09:00 AM

Project: Seaview Elementary School

Analytical Results

Client Sample Description SES-FB
Field Blank
Collected: 9/3/2021 8:05:00 AM
Lab ID: 012110575-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 ppb	9/29/2021 VD	9/29/2021 VD 13:47

Client Sample Description SES-DW-A02
Collected: 9/3/2021 8:07:00 AM
Lab ID: 012110575-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.43	1.00 ppb	9/29/2021 VD	9/29/2021 VD 13:52

Client Sample Description SES-DW-A01
Collected: 9/3/2021 8:08:00 AM
Lab ID: 012110575-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 ppb	9/29/2021 VD	9/29/2021 VD 13:53

Client Sample Description SES-DW-MAIN
Collected: 9/3/2021 8:12:00 AM
Lab ID: 012110575-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.86	1.00 ppb	9/29/2021 VD	9/29/2021 VD 13:54

Client Sample Description SES-SO-MAINA
Collected: 9/3/2021 8:12:00 AM
Lab ID: 012110575-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	15.0	1.00 ppb	9/29/2021 VD	9/29/2021 VD 13:59

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order:	012110575
CustomerID:	EPIC62
CustomerPO:	NJ-DOE
ProjectID:	NJ DOE

Attn: **James Eberts**
Epic Environmental Services, LLC
80 Fork Bridge Road
Pittsgrove, NJ 08318

Phone: (856) 205-1077
 Fax: (856) 205-0413
 Received: 9/8/2021 09:00 AM

Project: Seaview Elementary School

Analytical Results

Client Sample Description SES-SO-MAINB		Collected: 9/3/2021 8:14:00 AM		Lab ID: 012110575-0010	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.15	1.00 ppb	9/29/2021 VD	9/29/2021 VD 14:00

Client Sample Description SES-DW-NUR		Collected: 9/3/2021 8:15:00 AM		Lab ID: 012110575-0012	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 ppb	9/29/2021 VD	9/29/2021 VD 14:02

Client Sample Description SES-SO-NUR		Collected: 9/3/2021 8:16:00 AM		Lab ID: 012110575-0014	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.85	1.00 ppb	9/29/2021 VD	9/29/2021 VD 14:03

Client Sample Description SES-SO-NURR		Collected: 9/3/2021 8:19:00 AM		Lab ID: 012110575-0016	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.13	1.00 ppb	9/29/2021 VD	9/29/2021 VD 14:05

Client Sample Description SES-SO-MUSIC		Collected: 9/3/2021 8:21:00 AM		Lab ID: 012110575-0018	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.87	1.00 ppb	9/29/2021 VD	9/29/2021 VD 14:06

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012110575
 CustomerID: EPIC62
 CustomerPO: NJ-DOE
 ProjectID: NJ DOE

Attn: **James Eberts** Phone: (856) 205-1077
Epic Environmental Services, LLC Fax: (856) 205-0413
80 Fork Bridge Road Received: 9/8/2021 09:00 AM
Pittsgrove, NJ 08318

Project: Seaview Elementary School

Analytical Results

Client Sample Description SES-SO-FAC *Collected:* 9/3/2021 8:23:00 AM *Lab ID:* 012110575-0020

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	1.05	1.00 ppb	9/29/2021	VD	9/29/2021	VD 14:08

Client Sample Description SES-WC-CAF *Collected:* 9/3/2021 8:25:00 AM *Lab ID:* 012110575-0022

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 ppb	9/29/2021	VD	9/29/2021	VD 14:12

Client Sample Description SES-BF-CAF *Collected:* 9/3/2021 8:25:00 AM *Lab ID:* 012110575-0023

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 ppb	9/29/2021	VD	9/29/2021	VD 14:17

Client Sample Description SES-SO-KIT1 *Collected:* 9/3/2021 8:26:00 AM *Lab ID:* 012110575-0024

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	3.14	1.00 ppb	9/29/2021	VD	9/29/2021	VD 14:18

Client Sample Description SES-SO-KIT2 *Collected:* 9/3/2021 8:27:00 AM *Lab ID:* 012110575-0026

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	5.66	1.00 ppb	9/29/2021	VD	9/29/2021	VD 14:20



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077
Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012110575
CustomerID: EPIC62
CustomerPO: NJ-DOE
ProjectID: NJ DOE

Attn: **James Eberts** Phone: (856) 205-1077
Epic Environmental Services, LLC Fax: (856) 205-0413
80 Fork Bridge Road Received: 9/8/2021 09:00 AM
Pittsgrove, NJ 08318
Project: **Seaview Elementary School**

Analytical Results

Client Sample Description SES-SO-KIT3 **Collected:** 9/3/2021 8:29:00 AM **Lab ID:** 012110575-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.73	1.00 ppb	9/29/2021 VD	9/29/2021 VD 14:21

Client Sample Description SES-DW-GH1 **Collected:** 9/3/2021 8:35:00 AM **Lab ID:** 012110575-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 ppb	9/29/2021 VD	9/29/2021 VD 14:23

Client Sample Description SES-DW-GH2 **Collected:** 9/3/2021 8:36:00 AM **Lab ID:** 012110575-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.50	1.00 ppb	9/29/2021 VD	9/29/2021 VD 14:24

Client Sample Description SES-DW-GH3 **Collected:** 9/3/2021 8:37:00 AM **Lab ID:** 012110575-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 ppb	9/29/2021 VD	9/29/2021 VD 14:25

Client Sample Description SES-DW-GH4 **Collected:** 9/3/2021 8:39:00 AM **Lab ID:** 012110575-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.25	1.00 ppb	9/29/2021 VD	9/29/2021 VD 14:27

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012110575

CustomerID: EPIC62

CustomerPO: NJ-DOE

ProjectID: NJ DOE

Attn: **James Eberts**
Epic Environmental Services, LLC
80 Fork Bridge Road
Pittsgrove, NJ 08318

Phone: (856) 205-1077
 Fax: (856) 205-0413
 Received: 9/8/2021 09:00 AM

Project: Seaview Elementary School

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
SES-DW-GH5		9/3/2021 8:39:00 AM		012110575-0038	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.57	1.00 ppb	9/29/2021 VD	9/29/2021 VD 14:36
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
SES-DW-GH6		9/3/2021 8:41:00 AM		012110575-0040	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	3.15	1.00 ppb	9/29/2021 VD	9/29/2021 VD 14:40
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
SES-DW-GH7		9/3/2021 8:43:00 AM		012110575-0042	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.03	1.00 ppb	9/29/2021 VD	9/29/2021 VD 14:42
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
SES-DW-GH8		9/3/2021 8:44:00 AM		012110575-0044	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 ppb	9/29/2021 VD	9/29/2021 VD 14:43
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
SES-DW-A03		9/3/2021 8:47:00 AM		012110575-0046	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	13.9	1.00 ppb	9/29/2021 VD	9/29/2021 VD 14:45

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012110575

CustomerID: EPIC62

CustomerPO: NJ-DOE

ProjectID: NJ DOE

Attn: **James Eberts**
Epic Environmental Services, LLC
80 Fork Bridge Road
Pittsgrove, NJ 08318

Phone: (856) 205-1077
 Fax: (856) 205-0413
 Received: 9/8/2021 09:00 AM

Project: Seaview Elementary School

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
SES-DW-A05		9/3/2021 8:50:00 AM		012110575-0048	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	2.00	1.00 ppb	9/29/2021 VD	9/29/2021 VD 14:46
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
SES-DW-A12		9/3/2021 8:54:00 AM		012110575-0050	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	3.28	1.00 ppb	9/23/2021 KG	9/24/2021 JW 13:51
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
SES-DW-HALL2		9/3/2021 8:56:00 AM		012110575-0052	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	4.20	1.00 ppb	9/29/2021 VD	9/29/2021 VD 14:48
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
SES-DW-HALL1		9/3/2021 8:57:00 AM		012110575-0054	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	7.27	1.00 ppb	9/29/2021 VD	9/29/2021 VD 14:52
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
SES-SO-MEDIA		9/3/2021 9:01:00 AM		012110575-0056	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	6.03	1.00 ppb	9/29/2021 VD	9/29/2021 VD 14:54

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order:	012110575
CustomerID:	EPIC62
CustomerPO:	NJ-DOE
ProjectID:	NJ DOE

Attn: **James Eberts**
Epic Environmental Services, LLC
80 Fork Bridge Road
Pittsgrove, NJ 08318

Phone: (856) 205-1077
 Fax: (856) 205-0413
 Received: 9/8/2021 09:00 AM

Project: **Seaview Elementary School**

Analytical Results

Client Sample Description SES-DW-A14 **Collected:** 9/3/2021 9:03:00 AM **Lab ID:** 012110575-0058

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.36	1.00 ppb	9/29/2021 VD	9/29/2021 VD 14:55

Client Sample Description SES-DW-A09 **Collected:** 9/3/2021 9:05:00 AM **Lab ID:** 012110575-0060

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.86	1.00 ppb	9/29/2021 VD	9/29/2021 VD 14:56

Client Sample Description SES-DW-A16 **Collected:** 9/3/2021 9:06:00 AM **Lab ID:** 012110575-0062

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.11	1.00 ppb	9/29/2021 VD	9/29/2021 VD 15:01

Client Sample Description SES-DW-A11 **Collected:** 9/3/2021 9:08:00 AM **Lab ID:** 012110575-0064

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.73	1.00 ppb	9/29/2021 VD	9/29/2021 VD 15:02

Client Sample Description SES-DW-B01 **Collected:** 9/3/2021 9:10:00 AM **Lab ID:** 012110575-0066

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 ppb	9/29/2021 VD	9/29/2021 VD 15:04

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012110575

CustomerID: EPIC62

CustomerPO: NJ-DOE

ProjectID: NJ DOE

Attn: **James Eberts**
Epic Environmental Services, LLC
80 Fork Bridge Road
Pittsgrove, NJ 08318

Phone: (856) 205-1077
 Fax: (856) 205-0413
 Received: 9/8/2021 09:00 AM

Project: **Seaview Elementary School****Analytical Results**

Client Sample Description SES-DW-C12 **Collected:** 9/3/2021 9:13:00 AM **Lab ID:** 012110575-0068

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 ppb	9/29/2021 VD	9/29/2021 VD 15:05

Client Sample Description SES-DW-C14 **Collected:** 9/3/2021 9:14:00 AM **Lab ID:** 012110575-0070

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.22	1.00 ppb	9/29/2021 VD	9/29/2021 VD 15:10

Client Sample Description SES-DW-C16 **Collected:** 9/3/2021 9:16:00 AM **Lab ID:** 012110575-0072

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.41	1.00 ppb	9/29/2021 VD	9/29/2021 VD 15:11

Client Sample Description SES-DW-C07 **Collected:** 9/3/2021 9:18:00 AM **Lab ID:** 012110575-0074

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.23	1.00 ppb	9/29/2021 VD	9/29/2021 VD 15:13

Client Sample Description SES-DW-C18 **Collected:** 9/3/2021 9:22:00 AM **Lab ID:** 012110575-0076

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 ppb	9/29/2021 VD	9/29/2021 VD 15:14

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012110575

CustomerID: EPIC62

CustomerPO: NJ-DOE

ProjectID: NJ DOE

Attn: **James Eberts**
Epic Environmental Services, LLC
80 Fork Bridge Road
Pittsgrove, NJ 08318

Phone: (856) 205-1077
 Fax: (856) 205-0413
 Received: 9/8/2021 09:00 AM

Project: Seaview Elementary School

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
SES-DW-C09		9/3/2021 9:23:00 AM		012110575-0078			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 ppb	9/29/2021	VD	9/29/2021	VD 15:16
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
SES-DW-B04		9/3/2021 9:25:00 AM		012110575-0080			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 ppb	9/24/2021	VD	9/27/2021	VD 14:06
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
SES-DW-B03		9/3/2021 9:27:00 AM		012110575-0082			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 ppb	9/24/2021	VD	9/27/2021	VD 14:11
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
SES-DW-B02		9/3/2021 9:28:00 AM		012110575-0084			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	1.25	1.00 ppb	9/24/2021	VD	9/27/2021	VD 14:12
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
SES-DW-C08		9/3/2021 9:32:00 AM		012110575-0086			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	99.4	1.00 ppb	9/24/2021	VD	9/27/2021	VD 14:14

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012110575

CustomerID: EPIC62

CustomerPO: NJ-DOE

ProjectID: NJ DOE

Attn: **James Eberts**
Epic Environmental Services, LLC
80 Fork Bridge Road
Pittsgrove, NJ 08318

Phone: (856) 205-1077
 Fax: (856) 205-0413
 Received: 9/8/2021 09:00 AM

Project: Seaview Elementary School

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
SES-DW-C08 (FLUSH)		9/3/2021 9:33:00 AM		012110575-0087			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 ppb	9/30/2021	VD	9/30/2021	VD 23:00
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
SES-DW-C03		9/3/2021 9:34:00 AM		012110575-0088			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 ppb	9/24/2021	VD	9/27/2021	VD 14:15
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
SES-DW-C06		9/3/2021 9:36:00 AM		012110575-0090			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 ppb	9/24/2021	VD	9/27/2021	VD 14:17
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
SES-DW-C04		9/3/2021 9:37:00 AM		012110575-0092			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 ppb	9/24/2021	VD	9/27/2021	VD 14:18

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results