

**CAPE ENVIRONMENTAL LABORATORY, L.L.C.**

102 North Main • Cape May Court House, NJ 08210

D.E.P. Cert. #05679

Phone: 609-463-0077

Fax: 609-463-8977


CLIENT: Linwood Public Schools
SCHOOL: Belhaven Middle School
ADDRESS: 51 Belhaven Ave.
Linwood, NJ 08221

SAMPLE#: 48610
SAMPLE DATE: 3/29/16 8:55-9:23am
SAMPLED BY: CEL Tim Delp
RECEIVED: 3/29/2016

<u>ID #</u>	<u>LOCATION</u>	<u>CLIENT ID</u>	<u>ANALYSIS TIME</u>	<u>Pb ug/L</u>	<u>MCL</u>
-1	main lobby right	1R	3/30/2016 10:15am	<3.0	15ug/L
-2	main lobby left	1L	3/30/2016 10:15am	<3.0	15ug/L
-3	100 hall right	2R	3/30/2016 10:15am	<3.0	15ug/L
-4	100 hall left	2L	3/30/2016 10:15am	<3.0	15ug/L
-5	6th grade hall right	3R	3/30/2016 10:15am	<3.0	15ug/L
-6	6th grade hall left	3L	3/30/2016 10:15am	<3.0	15ug/L
-7	400 hall	4	3/30/2016 10:15am	<3.0	15ug/L
-8	500 hall	5	3/30/2016 10:15am	<3.0	15ug/L
-9	200 hall right	6R	3/30/2016 10:15am	<3.0	15ug/L
-10	200 hall left	6L	3/30/2016 10:15am	<3.0	15ug/L
-11	L hall right	7R	3/30/2016 10:15am	<3.0	15ug/L
-12	L hall left	7L	3/30/2016 10:15am	<3.0	15ug/L
-13	L hall bath right	8R	3/30/2016 10:15am	<3.0	15ug/L
-14	L hall bath left	8L	3/30/2016 10:15am	<3.0	15ug/L

To the best of our knowledge, all samples were first draw of the day.

Analysis Method SM 3113B



Timothy Delp, Laboratory Director

**CAPE ENVIRONMENTAL LABORATORY, L.L.C.**

102 North Main • Cape May Court House, NJ 08210

D.E.P. Cert. #05679

Phone: 609-463-0077

Fax: 609-463-8977


CLIENT: Linwood Public Schools
SCHOOL: Seaview Elementary School
ADDRESS: 2013 Wabash Ave.
Linwood, NJ 08221

SAMPLE#: 48611
SAMPLE DATE: 3/29/16 9:35-9:49am
SAMPLED BY: CEL Tim Delp
RECEIVED: 3/29/2016

<u>ID #</u>	<u>LOCATION</u>	<u>CLIENT ID</u>	<u>ANALYSIS TIME</u>	<u>Pb ug/L</u>	<u>MCL</u>
-1	gym hall 1 right	1R	3/30/2016 10:15am	<3.0	15ug/L
-2	gym hall 1 left	1L	3/30/2016 10:15am	<3.0	15ug/L
-3	gym hall 2 right	2R	3/30/2016 10:15am	<3.0	15ug/L
-4	gym hall 2 left	2L	3/30/2016 10:15am	<3.0	15ug/L
-5	gym hall 3 right	3R	3/30/2016 10:15am	<3.0	15ug/L
-6	gym hall 3 left	3L	3/30/2016 10:15am	<3.0	15ug/L
-7	gym hall 4 right	4R	3/30/2016 10:15am	<3.0	15ug/L
-8	gym hall 4 left	4L	3/30/2016 10:15am	<3.0	15ug/L
-9	A hall right	5R	3/30/2016 10:15am	<3.0	15ug/L
-10	A hall left	5L	3/30/2016 10:15am	<3.0	15ug/L

To the best of our knowledge, all samples were first draw of the day.

Analysis Method SM 3113B



Timothy Delp, Laboratory Director